

Абонент: _____ Договор N: _____
 Адрес: Луначарского 2 Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 180.00 м3/ч G
 M сет. воды= _____ т.сут Mгвс= _____ т.сут G обр max = 180.00 м3/ч G
 Тхв= 0.00 °С

Дата	t1	t2	dt	V1	M1	V2	M2	Mг	P1	P2	Qo	Qг	BHP	BOC	HC	
	°C	°C	°C	m3	т	m3	т	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч		
16/12/20	75.90	62.54	13.36	336.42	327.83	336.81	330.81	-2.98	3.83	6.70	4.362	-0.186	24	0	*	
17/12/20	70.87	58.94	11.93	330.30	322.86	331.07	325.75	-2.89	4.70	6.70	3.838	-0.170	24	0	*	
18/12/20	70.45	58.69	11.76	331.51	324.12	332.21	326.95	-2.83	4.84	5.47	3.802	-0.166	24	0	*	
19/12/20	73.86	60.83	13.03	330.40	322.42	330.86	325.27	-2.85	6.22	7.49	4.189	-0.173	24	0	*	
20/12/20	78.12	63.33	14.79	327.20	318.41	327.24	321.25	-2.84	5.27	5.05	4.715	-0.180	24	0	*	
21/12/20	78.70	63.78	14.92	326.75	317.87	326.80	320.78	-2.91	5.65	6.70	4.737	-0.186	24	0	*	
22/12/20	77.53	63.17	14.36	325.26	316.64	325.43	319.53	-2.89	3.81	6.70	4.529	-0.182	24	0	*	
23/12/20	74.71	61.44	13.27	325.08	317.00	325.53	319.93	-2.93	2.48	6.70	4.178	-0.180	24	0	*	
24/12/20	73.50	60.68	12.82	328.03	320.10	328.53	323.00	-2.90	2.15	6.70	4.078	-0.176	24	0	*	
25/12/20	74.08	61.28	12.80	328.93	320.90	329.39	323.72	-2.82	3.18	6.41	4.088	-0.173	24	0	*	
26/12/20	72.77	60.23	12.54	326.40	318.71	327.00	321.59	-2.88	5.90	7.57	3.982	-0.173	24	0		
27/12/20	73.04	60.51	12.53	326.60	318.83	327.24	321.72	-2.89	4.65	6.79	3.980	-0.175	24	0		
28/12/20	74.20	61.74	12.46	333.15	324.99	333.75	327.95	-2.96	3.12	7.43	4.021	-0.183	24	0		
29/12/20	74.01	61.47	12.54	330.44	322.36	331.03	325.38	-3.02	3.54	9.64	4.001	-0.186	24	0	*	
30/12/20	74.18	61.37	12.81	329.12	321.05	329.71	324.00	-2.95	3.38	6.70	4.092	-0.181	24	0	*	
31/12/20	73.95	61.20	12.75	329.57	321.55	330.12	324.52	-2.97	2.49	10.37	4.049	-0.182	24	0	*	
01/01/21	74.28	61.49	12.79	329.23	321.07	329.77	324.07	-3.00	2.30	9.25	4.063	-0.185	24	0	*	
02/01/21	74.30	61.58	12.72	329.73	321.63	330.27	324.57	-2.94	2.26	9.64	4.046	-0.181	24	0	*	
03/01/21	73.89	61.20	12.69	328.41	320.38	328.90	323.38	-3.00	2.41	12.93	3.997	-0.184	24	0	*	
04/01/21	72.38	60.14	12.24	328.72	320.99	329.33	323.87	-2.88	1.90	8.24	3.888	-0.173	24	0	*	
05/01/21	73.02	60.66	12.36	328.95	321.08	329.52	323.97	-2.89	1.49	7.52	3.933	-0.175	24	0		
06/01/21	72.86	60.39	12.47	328.09	320.30	328.64	323.10	-2.80	1.65	3.14	3.985	-0.169	24	0	*	
07/01/21	72.57	60.09	12.48	327.98	320.24	328.55	323.03	-2.79	3.80	2.29	4.006	-0.167	24	0		
08/01/21	70.47	58.61	11.86	323.22	315.98	323.99	318.88	-2.90	4.54	5.43	3.738	-0.170	24	0	*	
09/01/21	73.23	61.47	11.76	354.48												

Представитель абонента	Представитель теплоснабж. организации
------------------------	---------------------------------------