

16/12/20Г.-15/01/21Г.

TXB= 0.00°C G3 max = 2.00 м3/ч G3 min = 1.00 м3/ч

Заводской номер 00179191 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 1 БД 1 ФТ=0 ТЗ=1 КС=0хEFE8 ПО 2.7

| Дата     | t1    | t2    | dt    | M1      | M2      | Mг   | Qo     | ВНП | ВОС | НС |  |  |
|----------|-------|-------|-------|---------|---------|------|--------|-----|-----|----|--|--|
|          | °C    | °C    | °C    | т       | т       | т    | Гкал   | ч   | ч   |    |  |  |
| 16/12/20 | 74.11 | 60.76 | 13.35 | 126.45  | 126.26  | 0.19 | 1.689  | 24  | 0   |    |  |  |
| 17/12/20 | 69.26 | 57.26 | 12.00 | 124.16  | 123.89  | 0.27 | 1.488  | 24  | 0   |    |  |  |
| 18/12/20 | 68.74 | 56.73 | 12.01 | 121.71  | 121.49  | 0.22 | 1.462  | 24  | 0   |    |  |  |
| 19/12/20 | 71.99 | 58.61 | 13.38 | 119.31  | 118.99  | 0.32 | 1.597  | 24  | 0   |    |  |  |
| 20/12/20 | 76.18 | 61.29 | 14.89 | 117.99  | 117.68  | 0.31 | 1.758  | 24  | 0   |    |  |  |
| 21/12/20 | 76.77 | 61.87 | 14.90 | 119.91  | 119.52  | 0.39 | 1.787  | 24  | 0   |    |  |  |
| 22/12/20 | 75.67 | 61.27 | 14.40 | 120.58  | 120.31  | 0.27 | 1.737  | 24  | 0   |    |  |  |
| 23/12/20 | 72.95 | 59.39 | 13.56 | 119.25  | 118.90  | 0.35 | 1.617  | 24  | 0   |    |  |  |
| 24/12/20 | 71.71 | 58.60 | 13.11 | 120.40  | 120.26  | 0.14 | 1.579  | 24  | 0   |    |  |  |
| 25/12/20 | 72.32 | 59.39 | 12.93 | 123.79  | 123.56  | 0.23 | 1.598  | 24  | 0   |    |  |  |
| 26/12/20 | 71.06 | 58.39 | 12.67 | 122.61  | 122.38  | 0.23 | 1.552  | 24  | 0   |    |  |  |
| 27/12/20 | 71.31 | 58.69 | 12.62 | 123.16  | 123.03  | 0.13 | 1.553  | 24  | 0   |    |  |  |
| 28/12/20 | 72.42 | 59.85 | 12.57 | 127.15  | 126.94  | 0.21 | 1.599  | 24  | 0   |    |  |  |
| 29/12/20 | 72.27 | 59.72 | 12.55 | 126.46  | 126.22  | 0.24 | 1.587  | 24  | 0   |    |  |  |
| 30/12/20 | 72.43 | 59.68 | 12.75 | 125.47  | 125.19  | 0.28 | 1.601  | 24  | 0   |    |  |  |
| 31/12/20 | 72.20 | 59.45 | 12.75 | 124.18  | 124.01  | 0.17 | 1.582  | 24  | 0   |    |  |  |
| 01/01/21 | 72.50 | 59.71 | 12.79 | 124.16  | 123.84  | 0.32 | 1.585  | 24  | 0   |    |  |  |
| 02/01/21 | 72.52 | 59.78 | 12.74 | 124.02  | 123.87  | 0.15 | 1.583  | 24  | 0   |    |  |  |
| 03/01/21 | 72.14 | 59.38 | 12.76 | 122.82  | 122.66  | 0.16 | 1.568  | 24  | 0   |    |  |  |
| 04/01/21 | 70.67 | 58.25 | 12.42 | 122.77  | 122.65  | 0.12 | 1.521  | 24  | 0   |    |  |  |
| 05/01/21 | 71.29 | 58.70 | 12.59 | 122.67  | 122.59  | 0.08 | 1.546  | 24  | 0   |    |  |  |
| 06/01/21 | 71.13 | 58.49 | 12.64 | 121.88  | 121.78  | 0.10 | 1.540  | 24  | 0   |    |  |  |
| 07/01/21 | 70.84 | 58.26 | 12.58 | 121.76  | 121.59  | 0.17 | 1.528  | 24  | 0   |    |  |  |
| 08/01/21 | 68.91 | 56.42 | 12.49 | 113.99  | 113.88  | 0.11 | 1.423  | 24  | 0   |    |  |  |
| 09/01/21 | 71.44 | 58.41 | 13.03 | 118.84  | 118.71  | 0.13 | 1.547  | 24  | 0   |    |  |  |
| 10/01/21 | 71.25 | 58.53 | 12.72 | 119.64  | 119.50  | 0.14 | 1.522  | 24  | 0   |    |  |  |
| 11/01/21 | 73.24 | 59.69 | 13.55 | 119.90  | 119.65  | 0.25 | 1.626  | 24  | 0   |    |  |  |
| 12/01/21 | 77.99 | 62.38 | 15.61 | 113.08  | 112.73  | 0.35 | 1.768  | 24  | 0   |    |  |  |
| 13/01/21 | 78.06 | 62.16 | 15.90 | 111.40  | 111.30  | 0.10 | 1.772  | 24  | 0   |    |  |  |
| 14/01/21 | 75.53 | 60.94 | 14.59 | 116.56  | 116.42  | 0.14 | 1.701  | 24  | 0   |    |  |  |
| 15/01/21 | 69.71 | 57.24 | 12.47 | 118.53  | 118.42  | 0.11 | 1.477  | 24  | 0   |    |  |  |
| Итого:   |       |       |       | 3754.60 | 3748.22 | 6.38 | 49.493 | 744 | 0   |    |  |  |
| Средние: | 72.53 | 59.33 | 13.20 |         |         |      |        |     |     |    |  |  |

Период нормальной работы 744ч  
Период отсутств.счета тепл.энергии 0ч  
Время работы прибора после сброса 5131ч

|                        |                                      |
|------------------------|--------------------------------------|
| Представитель абонента | Представитель теплоснабж.организации |
|------------------------|--------------------------------------|