

Абонент: _____ Договор N: _____
 Адрес: ул. Губкина д.30 Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 120.00 м3/ч G под min = 0.32 м3/ч
 М сет. воды = _____ т.сут Mгвс = _____ т.сут G обр max = 120.00 м3/ч G обр min = 0.32 м3/ч
 tжв = 5.00°C

Заводской номер 00284441 ВВОД 1 СХЕМА ПОДКЛЮЧЕНИЯ 3 БД 1 ФТ=0 ТЗ=0 КС=0х0D43 ПО 2.7

Дата	t1	t2	dt	M1	M2	Mr	Qo	BHP	BOC	HC
	°C	°C	°C	т	т	т	Гкал	ч	ч	
16/12/20	71.42	52.44	18.98	148.81	152.22	-3.41	2.823	24	0	
17/12/20	67.48	50.04	17.44	147.10	150.29	-3.19	2.565	24	0	
18/12/20	67.40	50.18	17.22	148.25	151.31	-3.06	2.550	24	0	
19/12/20	73.03	52.94	20.09	148.24	151.94	-3.70	2.980	24	0	
20/12/20	77.96	55.65	22.31	149.46	153.79	-4.33	3.334	24	0	
21/12/20	77.58	55.45	22.13	149.57	153.84	-4.27	3.311	24	0	
22/12/20	76.49	55.09	21.40	149.75	153.77	-4.02	3.205	24	0	
23/12/20	71.74	52.75	18.99	150.90	154.35	-3.45	2.868	24	0	
24/12/20	66.38	49.38	17.00	148.26	151.15	-2.89	2.519	24	0	
25/12/20	67.11	49.63	17.48	145.83	148.79	-2.96	2.552	24	0	
26/12/20	67.07	49.45	17.62	145.24	148.32	-3.08	2.559	24	0	
27/12/20	65.77	48.77	17.00	145.62	148.42	-2.80	2.474	24	0	
28/12/20	64.49	48.22	16.27	145.02	147.67	-2.65	2.358	24	0	
29/12/20	65.48	48.63	16.85	145.02	147.84	-2.82	2.446	24	0	
30/12/20	69.58	50.91	18.67	147.36	150.63	-3.27	2.751	24	0	
31/12/20	71.14	52.35	18.79	149.28	152.77	-3.49	2.805	24	0	
01/01/21	68.45	50.83	17.62	149.49	152.64	-3.15	2.635	24	0	
02/01/21	67.27	50.09	17.18	150.08	153.13	-3.05	2.578	24	0	
03/01/21	67.19	49.90	17.29	150.36	153.43	-3.07	2.600	24	0	
04/01/21	65.62	49.03	16.59	148.53	151.47	-2.94	2.464	24	0	
05/01/21	64.91	48.45	16.46	148.32	151.24	-2.92	2.440	24	0	
06/01/21	66.54	49.29	17.25	149.15	152.34	-3.19	2.573	24	0	
07/01/21	68.26	50.34	17.92	149.19	152.30	-3.11	2.673	24	0	
08/01/21	67.50	49.97	17.53	149.24	152.33	-3.09	2.618	24	0	
09/01/21	65.71	49.11	16.60	149.34	152.21	-2.87	2.480	24	0	
10/01/21	64.82	48.74	16.08	148.70	151.52	-2.82	2.388	24	0	
11/01/21	71.26	51.86	19.40	147.77	151.20	-3.43	2.867	24	0	
12/01/21	78.54	55.93	22.61	147.84	151.93	-4.09	3.348	24	0	
13/01/21	79.31	57.00	22.31	154.73	159.27	-4.54	3.455	24	0	
14/01/21	73.12	53.77	19.35	154.39	158.39	-4.00	2.989	24	0	
15/01/21	65.26	49.84	15.42	159.77	163.05	-3.28	2.464	24	0	
Итого:				4620.61	4723.55	-102.94	84.672	744	0	
Средние:	69.48	51.16	18.31							

Период нормальной работы 744ч
Период отсутств.счета тепл.энергии 0ч
Время работы прибора после сброса 19682ч

Представитель абонента	Представитель теплоснабж. организации
------------------------	---------------------------------------