

ОТЧЕТ
о суточных параметрах теплоснабжения
16/12/20г.-15/01/21г.

Абонент: _____ Договор N: _____
 Адрес: Новоселова 14 Тип расходомера: _____
 Тепловычислитель ВКТ-7 сет. N 001 Пределы измерений: _____
 Договорные расходы: G под max = 180.00 м3/ч G
 M сет. воды = _____ т.сут Mгвс = _____ т.сут G обр max = 180.00 м3/ч G
 Тхв = 0.00 °C G3 max = 40.00 м3/ч G

Дата	t1	t2	dt	V1	M1	V2	M2	V3	Mг	P1	P2	Qo	Qг	BHP	BOC	HC		
	°C	°C	°C	m3	т	m3	т	m3	т	кг/см2	кг/см2	Гкал	Гкал	ч	ч			
16/12/20	69.69	53.83	15.86	263.84	258.10	260.10	256.69	0.00	1.41	6.20	16.67	4.035	0.076	24	0	*		
17/12/20	65.95	52.15	13.80	280.78	275.24	276.79	273.42	0.00	1.82	6.20	16.67	3.738	0.095	24	0	*		
18/12/20	66.83	53.49	13.34	300.69	294.61	296.53	292.76	0.00	1.85	6.20	16.68	3.862	0.099	24	0	*		
19/12/20	70.34	54.60	15.74	274.67	268.58	270.67	267.05	0.00	1.53	6.20	16.67	4.166	0.084	24	0	*		
20/12/20	73.66	54.60	19.06	236.47	230.77	232.55	229.47	0.00	1.30	6.20	16.65	4.349	0.071	24	0	*		
21/12/20	73.60	54.66	18.94	240.00	234.22	235.84	232.70	0.00	1.52	6.20	16.66	4.387	0.083	24	0	*		
22/12/20	73.78	55.20	18.58	246.00	240.06	241.91	238.61	0.00	1.45	6.20	16.67	4.408	0.080	24	0	*		
23/12/20	70.84	53.69	17.15	246.35	240.83	242.32	239.20	0.00	1.63	6.20	16.67	4.075	0.088	24	0	*		
24/12/20	69.67	53.15	16.52	245.42	240.08	241.44	238.36	0.00	1.72	6.20	16.67	3.912	0.092	24	0	*		
25/12/20	67.45	53.01	14.44	275.52	269.84	271.30	267.84	0.00	2.00	6.20	16.65	3.835	0.106	24	0	*		
26/12/20	66.28	52.75	13.53	290.50	284.73	286.20	282.63	0.00	2.10	6.20	16.65	3.786	0.111	24	0	*		
27/12/20	64.93	52.03	12.90	290.90	285.31	286.64	283.15	0.00	2.16	6.20	16.64	3.617	0.113	24	0	*		
28/12/20	65.57	51.68	13.89	271.76	266.45	267.59	264.39	0.00	2.06	6.20	16.65	3.642	0.107	24	0	*		
29/12/20	68.34	52.77	15.57	255.91	250.54	251.83	248.67	0.00	1.87	6.20	16.65	3.843	0.099	24	0	*		
30/12/20	71.09	54.10	16.99	249.17	243.55	245.09	241.88	0.00	1.67	6.20	16.65	4.086	0.091	24	0	*		
31/12/20	70.63	53.86	16.77	250.10	244.53	245.99	242.79	0.00	1.74	6.20	16.66	4.045	0.094	24	0	*		
01/01/21	71.30	54.77	16.53	258.62	252.78	254.53	251.13	0.00	1.65	6.20	16.66	4.124	0.091	24	0	*		
02/01/21	71.30	54.85	16.45	258.52	252.64	254.44	251.01	0.00	1.63	6.20	16.66	4.100	0.090	24	0	*		
03/01/21	71.12	54.65	16.47	256.23	250.38	252.16	248.76	0.00	1.62	6.20	16.64	4.071	0.089	24	0	*		
04/01/21	70.74	54.39	16.35	254.97	249.25	250.90	247.55	0.00	1.70	6.20	16.65	4.019	0.093	24	0	*		
05/01/21	67.73	52.94	14.79	264.91	259.42	260.79	257.49	0.00	1.93	6.20	16.64	3.779	0.103	24	0	*		
06/01/21	66.21	52.08	14.13	269.58	264.23	265.48	262.24	0.00	1.99	6.20	16.65	3.677	0.104	24	0	*		
07/01/21	66.20	51.99	14.21	26														

Средние:	69.47	53.55	15.91								6.20	16.65					
----------	-------	-------	-------	--	--	--	--	--	--	--	------	-------	--	--	--	--	--

Представитель абонента	Представитель теплоснабж. организации
------------------------	---------------------------------------