

16/01/21г.-15/02/21г.

Договор N: _____

Тип расходомера: _____

Пределы измерений:

$G_{\text{под max}} = 120.00 \text{ м}^3/\text{ч}$ $G_{\text{под min}} = 0.32 \text{ м}^3/\text{ч}$

$G_{\text{обp max}} = 120.00 \text{ м}^3/\text{ч}$ $G_{\text{обp min}} = 0.32 \text{ м}^3/\text{ч}$

$$G3 \text{ max} = 12.00 \text{ м}^3/\text{ч} \quad G3 \text{ min} = 0.12 \text{ м}^3/\text{ч}$$

ВВОД 1

СХЕМА ПОДКЛЮЧЕНИЯ 3

БД 1

$$\Phi T = 0$$

T3=1

KC=0xB0FD

ПО 2.7

Дата	t1	t2	dt	M1	M2	Mг	Qo	ВНР	ВОС	НС
	°C	°C	°C	т	т	т	Гкал	ч	ч	

16/01/21	71.55	54.70	16.85	136.63	137.27	-0.64	2.301	24	0	*
17/01/21	72.91	55.28	17.63	136.39	137.02	-0.63	2.404	24	0	*
18/01/21	77.78	58.40	19.38	139.19	139.83	-0.64	2.696	24	0	*
19/01/21	79.10	59.36	19.74	139.98	140.59	-0.61	2.763	24	0	*
20/01/21	78.55	58.86	19.69	139.95	140.66	-0.71	2.759	24	0	*
21/01/21	77.06	57.92	19.14	139.91	140.59	-0.68	2.678	24	0	*
22/01/21	76.99	58.33	18.66	141.14	141.86	-0.72	2.636	24	0	*
23/01/21	75.63	57.38	18.25	140.64	141.44	-0.80	2.567	24	0	*
24/01/21	74.63	58.34	16.29	156.20	157.30	-1.10	2.545	24	0	*
25/01/21	72.70	57.46	15.24	158.03	159.17	-1.14	2.410	24	0	*
26/01/21	71.62	55.82	15.80	144.77	145.68	-0.91	2.288	24	0	*
27/01/21	71.46	55.49	15.97	142.37	143.22	-0.85	2.271	24	0	*
28/01/21	72.15	55.90	16.25	141.98	142.75	-0.77	2.306	24	0	*
29/01/21	72.30	56.27	16.03	143.09	143.87	-0.78	2.294	24	0	*
30/01/21	72.18	56.62	15.56	146.00	146.90	-0.90	2.272	24	0	*
31/01/21	71.92	56.56	15.36	147.00	147.92	-0.92	2.258	24	0	*
01/02/21	71.74	56.42	15.32	146.60	147.54	-0.94	2.246	24	0	*
02/02/21	72.10	56.78	15.32	147.71	148.62	-0.91	2.261	24	0	*
03/02/21	72.34	56.70	15.64	144.44	145.23	-0.79	2.257	24	0	*
04/02/21	71.94	56.28	15.66	142.25	142.99	-0.74	2.227	24	0	*
05/02/21	72.12	57.36	14.76	152.80	153.85	-1.05	2.255	24	0	*
06/02/21	72.67	57.34	15.33	148.24	149.22	-0.98	2.274	24	0	*
07/02/21	75.01	57.20	17.81	134.19	134.92	-0.73	2.391	24	0	*
08/02/21	77.23	57.64	19.59	129.38	129.99	-0.61	2.535	24	0	*
09/02/21	79.10	58.41	20.69	129.85	130.23	-0.38	2.688	24	0	*
10/02/21	80.32	59.04	21.28	117.38	117.80	-0.42	2.501	24	0	*
11/02/21	78.08	58.07	20.01	131.93	132.40	-0.47	2.639	24	0	*
12/02/21	72.78	55.53	17.25	137.70	138.39	-0.69	2.373	24	0	*
13/02/21	64.83	51.09	13.74	143.38	144.23	-0.85	1.967	24	0	*
14/02/21	65.82	51.32	14.50	140.50	141.35	-0.85	2.035	24	0	*
15/02/21	70.73	53.66	17.07	131.64	131.86	-0.22	2.245	24	0	*

Итого:				4371.26	4394.69	-23.43	74.342	744	0	
--------	--	--	--	---------	---------	--------	--------	-----	---	--

[illegible]

Период нормальной работы 744ч

Период отсутств.счета тепл.энергии 0ч

Время работы прибора после сброса 31244ч

Представитель абонента

Представитель теплоснабж. организации