

**ТС1, Суточный
с 20.12.25 по 19.01.26**

Объект: г. Октябрьский, 34 микрорайон, 7
 Потребитель: АО "Жилуправление"
 Прибор: ТЭМ-106 Заводской номер: 3060225
 Формула: $Q = M1(h1 - h2)$
 Тип системы: Подача + расходомер

Система: 1
 ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	3.599999999	60	10	---
2	50	3.54	59	10	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
20.12.25	1.717	114.19	113.82	0.4	65.425	50.410	0.6	0.5	24.00
21.12.25	1.739	114.28	113.90	0.4	65.749	50.555	0.6	0.5	24.00
22.12.25	1.708	114.34	113.99	0.3	65.632	50.723	0.6	0.5	24.00
23.12.25	1.722	114.58	114.23	0.4	65.972	50.972	0.6	0.5	24.00
24.12.25	1.794	117.96	117.56	0.4	66.227	51.044	0.6	0.5	24.00
25.12.25	1.797	121.81	121.42	0.4	65.153	50.429	0.6	0.5	24.00
26.12.25	1.810	122.59	122.19	0.4	65.141	50.403	0.6	0.5	24.00
27.12.25	1.819	123.84	123.40	0.4	65.414	50.754	0.6	0.5	24.00
28.12.25	1.762	123.51	123.02	0.5	64.570	50.328	0.6	0.5	24.00
29.12.25	1.775	123.80	123.30	0.5	64.934	50.625	0.6	0.5	24.00
30.12.25	1.737	123.42	122.99	0.4	64.513	50.469	0.6	0.5	24.00
31.12.25	1.710	122.99	122.49	0.5	64.017	50.141	0.6	0.5	24.00
01.01.26	1.706	123.15	122.76	0.4	63.880	50.051	0.6	0.5	24.00
02.01.26	1.729	123.04	122.65	0.4	64.021	49.997	0.6	0.5	24.00
03.01.26	1.743	123.07	122.67	0.4	63.739	49.603	0.6	0.5	24.00
04.01.26	1.764	123.51	123.06	0.4	64.054	49.798	0.6	0.5	24.00
05.01.26	1.741	123.68	123.25	0.4	64.090	50.041	0.6	0.5	24.00
06.01.26	1.704	124.07	123.62	0.4	63.571	49.863	0.6	0.5	24.00
07.01.26	1.653	123.03	122.60	0.4	62.395	48.988	0.6	0.5	24.00
08.01.26	1.632	123.05	122.63	0.4	62.425	49.188	0.6	0.5	24.00
09.01.26	1.621	122.96	122.55	0.4	62.388	49.227	0.6	0.5	24.00
10.01.26	1.645	122.35	121.94	0.4	62.817	49.396	0.6	0.5	24.00
11.01.26	1.650	121.47	121.05	0.4	63.096	49.536	0.6	0.5	24.00
12.01.26	1.603	125.86	125.44	0.4	61.944	49.237	0.6	0.5	24.00
13.01.26	1.557	129.72	129.31	0.4	60.613	48.635	0.6	0.5	24.00
14.01.26	1.596	126.37	125.99	0.4	61.396	48.790	0.6	0.5	24.00
15.01.26	1.722	122.97	122.53	0.4	64.071	50.092	0.6	0.5	24.00
16.01.26	1.875	121.57	121.08	0.5	67.081	51.689	0.6	0.5	24.00
17.01.26	2.002	118.10	117.55	0.6	69.887	52.968	0.6	0.5	24.00
18.01.26	2.005	118.10	117.54	0.6	69.947	53.002	0.6	0.5	24.00
19.01.26	1.859	119.13	118.66	0.5	66.986	51.411	0.6	0.5	24.00
Итого	53.90	3772.5	3759.2	13.2	---	---	---	---	744.00
Среднее	---	---	---	---	64.55	50.27	0.6	0.5	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
19.12.25 24:00	4185.0	401744.7	384282.7	92664.4
19.01.26 24:00	4238.9	405517.2	388041.9	93408.4
Итого за период	53.9	3772.5	3759.2	744.0

Представитель абонента _____/_____

Представитель поставщика _____/_____