

**ТС1 Пульсар ДУ-40, Суточный
с 20.12.25 по 19.01.26**

Объект: г. Октябрьский, Горького, 32
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 05578927
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.12.25	66.4	54.6	88.938	1.030	24.00
21.12.25	66.2	54.4	88.781	1.026	24.00
22.12.25	66.5	55.0	90.375	1.025	24.00
23.12.25	66.0	54.7	90.234	1.002	24.00
24.12.25	71.4	57.9	90.164	1.184	24.00
25.12.25	73.6	59.4	90.227	1.245	24.00
26.12.25	70.2	57.2	90.578	1.154	24.00
27.12.25	68.2	55.8	90.633	1.098	24.00
28.12.25	67.9	55.7	90.586	1.085	24.00
29.12.25	68.2	56.0	90.586	1.085	24.00
30.12.25	68.3	56.1	90.555	1.082	24.00
31.12.25	68.1	56.0	90.555	1.069	24.00
01.01.26	67.9	55.9	90.711	1.071	24.00
02.01.26	67.8	55.6	90.422	1.084	24.00
03.01.26	67.7	55.2	89.719	1.093	24.00
04.01.26	68.0	55.5	89.867	1.098	24.00
05.01.26	68.3	56.0	90.000	1.089	24.00
06.01.26	67.0	55.1	90.055	1.047	24.00
07.01.26	59.6	49.5	87.492	0.873	24.00
08.01.26	65.4	53.7	87.547	1.004	24.00
09.01.26	65.4	53.6	87.289	1.003	24.00
10.01.26	64.9	53.3	87.516	0.995	24.00
11.01.26	65.0	53.4	87.398	0.997	24.00
12.01.26	63.4	52.3	87.383	0.949	24.00
13.01.26	62.1	51.3	87.352	0.922	24.00
14.01.26	63.8	52.4	87.344	0.975	24.00
15.01.26	67.5	54.9	87.250	1.078	24.00
16.01.26	71.1	57.1	87.203	1.196	24.00
17.01.26	72.0	57.6	87.078	1.225	24.00
18.01.26	71.0	56.9	86.914	1.194	24.00
19.01.26	67.8	54.8	87.008	1.102	24.00
Итого	---	---	2757.758	33.080	744.00
Среднее	67.3	55.1	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.12.25 24:00	69381.469	606.657	18761.000
19.01.26 24:00	72139.227	639.736	19505.000
Итого за период	2757.758	33.079	744.000

Представитель абонента _____/_____

Представитель поставщика _____/_____