

**ТС1, Суточный
с 20.12.25 по 19.01.26**

Объект: г. Октябрьский, Девонская, 16
 Потребитель: АО "Жилуправление"
 Прибор: Вэлт ТСРВ-024М Заводской номер: 902533
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
20.12.25	65.58	51.64	13.94	216.54	216.54	0	0.0	0.0	219.29	220.93	-1.64	3.016	24.00
21.12.25	65.44	51.28	14.16	213.39	213.39	0	0.0	0.0	216.09	217.68	-1.59	3.019	24.00
22.12.25	63.99	50.45	13.54	211.31	211.31	0.00	0.0	0.0	213.83	215.46	-1.62	2.858	24.00
23.12.25	66.28	52.14	14.14	216.60	216.60	0.00	0.0	0.0	219.45	221.05	-1.60	3.036	24.00
24.12.25	69.90	53.42	16.48	205.30	205.30	0.00	0.0	0.0	208.40	209.68	-1.28	3.382	24.00
25.12.25	72.86	54.81	18.05	201.75	201.75	0	0.0	0.0	205.13	206.21	-1.08	3.640	24.00
26.12.25	69.75	53.18	16.57	204.07	204.07	0	0.0	0.0	207.13	208.38	-1.25	3.378	24.00
27.12.25	67.40	51.64	15.76	202.92	202.92	0	0.0	0.0	205.71	207.03	-1.32	3.197	24.00
28.12.25	67.20	51.73	15.47	204.59	204.59	0	0.0	0.0	207.37	208.76	-1.39	3.162	24.00
29.12.25	67.52	52.02	15.50	203.55	203.55	0	0.0	0.0	206.35	207.74	-1.39	3.151	24.00
30.12.25	67.61	52.30	15.31	205.26	205.26	0	0.0	0.0	208.09	209.50	-1.41	3.140	24.00
31.12.25	67.80	52.41	15.39	204.08	204.08	0	0.0	0.0	206.92	208.30	-1.38	3.137	24.00
01.01.26	67.46	52.18	15.28	204.54	204.54	0	0.0	0.0	207.36	208.75	-1.39	3.122	24.00
02.01.26	67.46	51.97	15.49	203.69	203.69	0.00	0.0	0.0	206.49	207.87	-1.38	3.153	24.00
03.01.26	67.07	51.50	15.57	203.77	203.77	0	0.0	0.0	206.52	207.90	-1.38	3.168	24.00
04.01.26	67.21	51.63	15.58	203.32	203.32	0	0.0	0.0	206.08	207.46	-1.38	3.165	24.00
05.01.26	67.60	52.03	15.57	203.72	203.72	0.00	0.0	0.0	206.53	207.91	-1.38	3.167	24.00
06.01.26	66.65	51.53	15.12	203.37	203.37	0	0.0	0.0	206.08	207.48	-1.40	3.073	24.00
07.01.26	64.36	50.03	14.33	185.58	185.60	-0.02	0.0	0.0	187.83	189.21	-1.38	2.666	22.00
08.01.26	64.81	50.47	14.34	204.86	204.86	0	0.0	0.0	207.37	208.90	-1.53	2.934	24.00
09.01.26	64.53	50.28	14.25	203.36	203.36	0.00	0.0	0.0	205.83	207.35	-1.52	2.895	24.00
10.01.26	64.50	50.22	14.28	204.35	204.35	0	0.0	0.0	206.84	208.35	-1.51	2.915	24.00
11.01.26	64.39	50.09	14.30	203.52	203.52	0	0.0	0.0	205.97	207.50	-1.53	2.906	24.00
12.01.26	63.44	49.66	13.78	204.62	204.62	0	0.0	0.0	207.01	208.56	-1.55	2.815	24.00
13.01.26	61.68	48.50	13.18	203.84	203.84	0.00	0.0	0.0	206.02	207.66	-1.64	2.684	24.00
14.01.26	62.89	49.44	13.45	209.36	209.36	0.00	0.0	0.0	211.72	213.39	-1.67	2.805	24.00
15.01.26	65.94	51.07	14.87	205.85	205.85	0	0.0	0.0	208.50	209.99	-1.49	3.055	24.00
16.01.26	69.61	52.93	16.68	204.64	204.64	0.00	0.0	0.0	207.67	208.97	-1.30	3.414	24.00
17.01.26	71.48	53.59	17.89	201.62	201.62	0.00	0.0	0.0	204.81	205.97	-1.16	3.606	24.00
18.01.26	70.66	53.09	17.57	201.30	201.30	0.00	0.0	0.0	204.39	205.58	-1.19	3.534	24.00
19.01.26	67.55	51.39	16.16	201.40	201.40	0	0.0	0.0	204.15	205.49	-1.34	3.252	24.00
Итого	---	---	---	6346.09	6346.10	-0.02	---	---	6430.93	6475.00	-44.07	96.444	742.00
Среднее	66.79	51.57	15.23	---	---	---	0.0	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мгс	Q, (Гкал)
19.12.25 24:00	-11660.40	6524.382
19.01.26 24:00	-11660.41	6620.826
Итого за период	---	96.444

Представитель абонента _____ / _____ Представитель поставщика _____ / _____