

**ТС1 Пульсар ДУ-40, Суточный
с 20.12.25 по 19.01.26**

Объект: г. Октябрьский, Комсомольская, 6
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 02816814
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.12.25	65.4	50.9	73.367	1.042	24.00
21.12.25	65.2	50.7	73.523	1.039	24.00
22.12.25	65.5	51.3	74.953	1.041	24.00
23.12.25	65.0	51.2	74.992	1.015	24.00
24.12.25	70.4	53.8	74.891	1.214	24.00
25.12.25	72.3	55.1	74.656	1.255	24.00
26.12.25	69.0	53.3	75.008	1.155	24.00
27.12.25	67.1	52.1	75.062	1.101	24.00
28.12.25	66.9	52.0	74.977	1.092	24.00
29.12.25	67.1	52.3	74.773	1.088	24.00
30.12.25	67.2	52.4	74.625	1.085	24.00
31.12.25	67.0	52.3	74.648	1.076	24.00
01.01.26	66.8	52.1	74.719	1.081	24.00
02.01.26	66.8	51.7	74.656	1.101	24.00
03.01.26	66.6	51.3	73.992	1.106	24.00
04.01.26	66.9	51.6	74.062	1.111	24.00
05.01.26	67.3	52.1	74.117	1.104	24.00
06.01.26	65.8	51.3	74.383	1.060	24.00
07.01.26	58.8	46.4	73.273	0.885	24.00
08.01.26	64.3	50.1	73.172	1.022	24.00
09.01.26	64.3	50.1	72.930	1.020	24.00
10.01.26	63.8	49.8	73.211	1.009	24.00
11.01.26	64.0	49.9	73.133	1.009	24.00
12.01.26	62.3	49.0	73.328	0.956	24.00
13.01.26	61.1	48.3	73.438	0.926	24.00
14.01.26	62.8	49.2	73.289	0.979	24.00
15.01.26	66.5	51.3	73.117	1.085	24.00
16.01.26	70.1	53.2	73.070	1.205	24.00
17.01.26	70.8	53.4	72.602	1.235	24.00
18.01.26	69.7	52.8	72.453	1.201	24.00
19.01.26	66.7	51.2	72.695	1.106	24.00
Итого	---	---	2291.117	33.400	744.00
Среднее	66.2	51.4	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.12.25 24:00	70753.500	752.833	23855.000
19.01.26 24:00	73044.617	786.233	24599.000
Итого за период	2291.117	33.400	744.000

Представитель абонента _____/_____

Представитель поставщика _____/_____