

**ТС1 Пульсар ДУ-40, Суточный
с 20.12.25 по 19.01.26**

Объект: Чапаева д. 7
Потребитель: АО "Жилуправление"
Прибор: 405 Заводской номер: 5578692

ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.12.25	65.7	49.5	39.559	0.627	24.00
21.12.25	65.4	49.2	39.469	0.629	24.00
22.12.25	65.8	49.8	40.133	0.628	24.00
23.12.25	65.2	49.6	40.090	0.616	24.00
24.12.25	70.4	52.1	40.004	0.718	24.00
25.12.25	72.7	53.5	40.033	0.752	24.00
26.12.25	69.4	51.6	40.225	0.704	24.00
27.12.25	67.4	50.4	40.281	0.672	24.00
28.12.25	67.1	50.3	40.279	0.664	24.00
29.12.25	67.4	50.6	40.266	0.662	24.00
30.12.25	67.5	50.8	40.260	0.659	24.00
31.12.25	67.3	50.7	40.268	0.654	24.00
01.01.26	67.1	50.5	40.338	0.659	24.00
02.01.26	67.1	50.4	40.203	0.658	24.00
03.01.26	66.9	50.0	39.902	0.660	24.00
04.01.26	67.2	50.1	39.971	0.667	24.00
05.01.26	67.5	50.6	40.043	0.663	24.00
06.01.26	66.2	50.1	40.188	0.636	24.00
07.01.26	59.0	45.3	39.547	0.530	24.00
08.01.26	64.6	48.8	39.492	0.614	24.00
09.01.26	64.6	48.7	39.379	0.614	24.00
10.01.26	64.1	48.4	39.510	0.609	24.00
11.01.26	64.3	48.5	39.498	0.609	24.00
12.01.26	62.7	47.8	39.535	0.579	24.00
13.01.26	61.4	47.0	39.514	0.559	24.00
14.01.26	63.0	47.8	39.473	0.590	24.00
15.01.26	66.7	49.8	39.402	0.651	24.00
16.01.26	70.3	51.7	39.352	0.716	24.00
17.01.26	71.1	51.9	39.105	0.735	24.00
18.01.26	70.2	51.3	38.969	0.717	24.00
19.01.26	67.0	49.7	39.102	0.661	24.00
Итого	---	---	1233.387	20.116	744.00
Среднее	66.5	49.9	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.12.25 24:00	31773.586	378.583	19472.000
19.01.26 24:00	33006.973	398.699	20216.000
Итого за период	1233.387	20.116	744.000

Представитель абонента _____/_____

Представитель поставщика _____/_____