

ТС1, Суточный
с 21.04.26 по 07.05.26

Объект: г. Октябрьский, Мичурина, 3
Потребитель: АО "Жилуправление"
Прибор: Вzlёт ТСРВ-024 Заводской номер: 900043
Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
21.04.26	45.20	39.12	6.08	100.66	100.64	0.02	0.432	0.600	101.65	101.37	0.28	0.607	24.000
22.04.26	45.48	38.96	6.52	100.50	100.48	0.01	0.428	0.600	101.50	101.21	0.29	0.651	24.000
23.04.26	45.24	38.69	6.55	100.31	100.30	0.01	0.430	0.600	101.29	101.01	0.29	0.652	24.000
24.04.26	45.01	38.49	6.52	100.28	100.27	0.00	0.429	0.600	101.26	100.98	0.28	0.649	24.000
25.04.26	44.80	38.29	6.51	100.28	100.27	0.00	0.429	0.600	101.24	100.97	0.28	0.648	24.000
26.04.26	45.49	38.70	6.79	100.25	100.24	0.00	0.427	0.600	101.24	100.95	0.29	0.676	24.000
27.04.26	45.87	39.12	6.75	100.25	100.24	0.01	0.431	0.600	101.26	100.96	0.29	0.671	24.000
28.04.26	45.29	38.75	6.54	100.31	100.30	0.01	0.432	0.600	101.30	101.01	0.29	0.651	24.000
29.04.26	45.88	39.18	6.70	100.56	100.55	0.00	0.433	0.600	101.58	101.29	0.29	0.668	24.000
30.04.26	45.32	38.81	6.51	100.53	100.52	0.01	0.430	0.600	101.52	101.23	0.29	0.650	24.000
01.05.26	45.71	39.17	6.54	101.61	101.59	0.01	0.430	0.600	102.63	102.33	0.30	0.659	24.000
02.05.26	45.84	39.28	6.56	100.81	100.80	0.01	0.432	0.600	101.83	101.54	0.29	0.656	24.000
03.05.26	45.42	39.03	6.39	100.82	100.81	0.00	0.433	0.600	101.81	101.54	0.28	0.639	24.000
04.05.26	40.67	35.40	5.27	70.27	70.26	0.01	0.333	0.600	70.97	70.77	0.20	0.440	18.833
05.05.26	17.67	16.42	1.25	0.00	0.00	0.00	0.109	0.600	0.00	0.00	0.00	0.000	0.000
06.05.26	15.72	14.81	0.91	0.00	0.00	0.00	0.109	0.600	0.00	0.00	0.00	0.000	0.000
07.05.26	15.25	14.44	0.81	0.00	0.00	0.00	0.109	0.600	0.00	0.00	0.00	0.000	0.000
Итого	---	---	---	1377.45	1377.28	0.16	---	---	1391.06	1387.15	3.91	8.917	330.833
Среднее	39.99	34.51	5.48	---	---	---	0.368	0.600	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____