

ТС1, Суточный
с 21.04.26 по 07.05.26

Объект: г. Октябрьский, Салавата батыра, 5
Потребитель: АО "Жилуправление"
Прибор: Вzlёт TCRB-024 Заводской номер: 800762
Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
21.04.26	45.12	38.45	6.67	143.73	143.58	0.14	0.590	0.549	145.12	144.59	0.53	0.963	24.000
22.04.26	45.32	38.27	7.05	143.47	143.33	0.13	0.590	0.549	144.87	144.33	0.54	1.015	24.000
23.04.26	45.18	38.00	7.18	143.22	143.08	0.14	0.590	0.549	144.60	144.06	0.54	1.033	24.000
24.04.26	44.97	37.79	7.18	143.18	143.04	0.13	0.590	0.549	144.54	144.02	0.52	1.032	24.000
25.04.26	44.75	37.61	7.14	143.21	143.07	0.14	0.590	0.549	144.57	144.04	0.53	1.027	24.000
26.04.26	45.32	37.90	7.42	143.11	142.99	0.12	0.590	0.549	144.51	143.96	0.55	1.065	24.000
27.04.26	45.77	38.33	7.44	143.06	142.93	0.12	0.590	0.549	144.48	143.92	0.56	1.068	24.000
28.04.26	45.32	38.11	7.21	143.14	143.00	0.13	0.590	0.549	144.54	143.98	0.55	1.036	24.000
29.04.26	45.75	38.72	7.03	154.08	153.93	0.15	0.590	0.549	155.61	155.02	0.59	1.089	24.000
30.04.26	45.41	38.55	6.86	155.67	155.59	0.08	0.590	0.549	157.19	156.69	0.50	1.071	24.000
01.05.26	45.52	38.66	6.86	156.24	156.16	0.07	0.590	0.549	157.78	157.27	0.51	1.074	24.000
02.05.26	45.74	38.87	6.87	156.28	156.21	0.06	0.590	0.549	157.83	157.33	0.50	1.075	24.000
03.05.26	45.40	38.59	6.81	156.33	156.26	0.07	0.590	0.549	157.87	157.37	0.50	1.066	24.000
04.05.26	44.35	38.35	6.00	154.36	154.28	0.07	0.590	0.549	155.83	155.39	0.44	0.952	24.000
05.05.26	23.31	23.31	0.00	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
06.05.26	19.74	19.77	-0.03	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
07.05.26	18.91	18.88	0.03	0.00	0.00	0.00	0.590	0.549	0.00	0.00	0.00	0.000	24.000
Итого	---	---	---	2079.07	2077.45	1.61	---	---	2099.34	2091.99	7.34	14.566	408.000
Среднее	40.93	35.19	5.75	---	---	---	0.590	0.549	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____