

ТС1, Суточный
с 21.04.26 по 07.05.26

Объект: г. Октябрьский, Фрунзе, 5
Потребитель: АО "Жилуправление"
Прибор: Вzlёт ТСРВ-024 Заводской номер: 801948
Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
21.04.26	43.96	39.58	4.38	93.05	93.05	0	0.704	0.632	93.70	93.94	-0.24	0.409	24.000
22.04.26	43.89	39.31	4.58	93.04	93.04	0	0.705	0.632	93.68	93.94	-0.26	0.426	24.000
23.04.26	43.80	39.18	4.62	93.07	93.07	0	0.705	0.632	93.69	93.96	-0.28	0.431	24.000
24.04.26	43.95	39.26	4.69	92.99	92.99	0	0.706	0.632	93.61	93.89	-0.28	0.437	24.000
25.04.26	43.75	39.05	4.70	93.04	93.04	0.00	0.706	0.633	93.65	93.94	-0.29	0.439	24.000
26.04.26	43.99	39.22	4.77	93.04	93.04	0.00	0.706	0.633	93.65	93.95	-0.30	0.444	24.000
27.04.26	44.00	39.32	4.68	93.02	93.02	0	0.705	0.632	93.64	93.94	-0.29	0.435	24.000
28.04.26	43.72	39.11	4.61	93.03	93.03	0	0.705	0.632	93.63	93.93	-0.30	0.429	24.000
29.04.26	43.54	38.94	4.60	92.55	92.56	-0.00	0.705	0.631	93.15	93.45	-0.29	0.424	23.667
30.04.26	44.28	39.59	4.69	94.07	94.07	0	0.707	0.638	94.71	94.99	-0.28	0.442	24.000
01.05.26	44.11	39.52	4.59	94.76	94.76	0	0.707	0.641	95.40	95.69	-0.28	0.435	24.000
02.05.26	44.38	39.74	4.64	94.72	94.72	0	0.707	0.641	95.38	95.65	-0.27	0.439	24.000
03.05.26	44.35	39.78	4.57	96.30	96.30	0	0.704	0.646	96.97	97.24	-0.27	0.441	24.000
04.05.26	40.34	36.71	3.63	67.66	67.66	0.00	0.547	0.541	68.11	68.30	-0.19	0.287	17.000
05.05.26	25.06	23.91	1.15	0.00	0.00	0.00	0.166	0.052	0.00	0.00	0.00	0.000	0.000
06.05.26	23.09	22.09	1.00	0.00	0.00	0.00	0.167	0.090	0.00	0.00	0.00	0.000	0.000
07.05.26	22.52	21.50	1.02	0.00	0.00	0.00	0.167	0.092	0.00	0.00	0.00	0.000	0.000
Итого	---	---	---	1284.34	1284.34	-0.00	---	---	1292.99	1296.81	-3.82	5.916	328.667
Среднее	40.16	36.22	3.94	---	---	---	0.601	0.531	---	---	---	---	---

Представитель абонента _____ / _____ Представитель поставщика _____ / _____