

**ТС1, Суточный
с 21.10.25 по 19.11.25**

Объект: г. Октябрьский, Островского, 47
 Потребитель: АО "Жилуправление"
 Прибор: Вzlёт ТСРВ-024М Заводской номер: 1600628
 Тип системы: А42-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
21.10.25	67.52	60.05	7.47	342.65	343.85	-1.20	0.0	0.0	349.96	349.76	0.20	2.555	24.00
22.10.25	67.43	60.37	7.06	361.90	363.23	-1.34	0.0	0.0	369.59	369.53	0.07	2.554	24.00
23.10.25	67.48	60.39	7.09	363.46	364.80	-1.34	0.0	0.0	371.20	371.13	0.07	2.577	24.00
24.10.25	66.90	59.87	7.03	363.07	364.37	-1.30	0.0	0.0	370.68	370.59	0.09	2.553	24.00
25.10.25	66.92	59.73	7.19	361.90	363.07	-1.16	0.0	0.0	369.50	369.24	0.26	2.599	24.00
26.10.25	66.73	59.53	7.20	375.91	376.97	-1.06	0.0	0.0	383.76	383.34	0.42	2.705	24.00
27.10.25	67.47	60.27	7.20	359.99	361.28	-1.29	0.0	0.0	367.66	367.53	0.13	2.590	24.00
28.10.25	65.33	58.65	6.68	361.62	362.85	-1.24	0.0	0.0	368.88	368.82	0.06	2.414	24.00
29.10.25	65.72	59.06	6.66	364.87	366.17	-1.30	0.0	0.0	372.27	372.26	0.01	2.430	24.00
30.10.25	65.71	59.06	6.65	365.04	366.46	-1.42	0.0	0.0	372.45	372.56	-0.12	2.425	24.00
31.10.25	65.92	59.05	6.87	360.92	362.14	-1.22	0.0	0.0	368.29	368.17	0.12	2.476	24.00
01.11.25	65.57	58.73	6.84	365.32	366.21	-0.89	0.0	0.0	372.70	372.24	0.46	2.469	23.50
02.11.25	66.88	59.71	7.17	360.45	361.06	-0.61	0.0	0.0	368.00	367.19	0.81	2.584	24.00
03.11.25	68.95	61.37	7.58	360.92	361.71	-0.79	0.0	0.0	368.92	368.17	0.74	2.735	24.00
04.11.25	67.62	60.14	7.48	358.29	359.17	-0.88	0.0	0.0	365.97	365.36	0.61	2.682	24.00
05.11.25	69.13	61.36	7.77	358.62	359.76	-1.15	0.0	0.0	366.61	366.19	0.41	2.787	24.00
06.11.25	67.98	60.62	7.36	361.33	362.76	-1.43	0.0	0.0	369.13	369.10	0.03	2.656	24.00
07.11.25	66.59	59.50	7.09	358.74	360.25	-1.51	0.0	0.0	366.20	366.33	-0.13	2.540	24.00
08.11.25	66.59	59.50	7.09	356.54	358.12	-1.58	0.0	0.0	363.95	364.16	-0.21	2.526	24.00
09.11.25	66.91	59.65	7.26	353.40	354.95	-1.55	0.0	0.0	360.81	360.97	-0.15	2.565	24.00
10.11.25	66.64	59.44	7.20	357.60	359.10	-1.50	0.0	0.0	365.04	365.15	-0.11	2.572	24.00
11.11.25	66.75	59.68	7.07	363.49	365.10	-1.60	0.0	0.0	371.08	371.30	-0.21	2.569	24.00
12.11.25	66.74	59.96	6.78	387.59	389.31	-1.72	0.0	0.0	395.67	395.97	-0.30	2.622	24.00
13.11.25	67.35	59.19	8.16	331.21	332.55	-1.34	0.0	0.0	338.23	338.16	0.07	2.593	24.00
14.11.25	66.75	55.76	10.99	218.50	218.98	-0.48	0.0	0.0	223.06	222.25	0.81	2.400	24.00
15.11.25	66.66	55.77	10.89	220.32	221.00	-0.67	0.0	0.0	224.91	224.30	0.61	2.397	24.00
16.11.25	66.88	55.85	11.03	220.16	220.88	-0.72	0.0	0.0	224.77	224.19	0.59	2.427	24.00
17.11.25	67.28	55.75	11.53	219.41	220.05	-0.64	0.0	0.0	224.06	223.34	0.72	2.529	24.00
18.11.25	66.79	55.41	11.38	217.87	218.53	-0.66	0.0	0.0	222.43	221.76	0.67	2.478	24.00
19.11.25	66.41	55.08	11.33	212.26	212.91	-0.65	0.0	0.0	216.65	216.02	0.63	2.402	24.00
Итого	---	---	---	9963.34	9997.59	-34.24	---	---	10172.43	10165.08	7.35	76.411	719.50
Среднее	66.92	58.95	7.97	---	---	---	0.0	0.0	---	---	---	---	---

Показания интеграторов

Дата	Мтс	Q, (Гкал)
20.10.25 24:00	16199.64	2691.510
19.11.25 24:00	16165.42	2767.921
Итого за период	---	76.411

Представитель абонента _____ / _____ Представитель поставщика _____ / _____