

**ТС1, Суточный
с 21.03.26 по 20.04.26**

Объект: г. Октябрьский, 35 мкр., 23
 Потребитель: АО "Жилуправление"
 Прибор: Вэлт ТСРВ-024М Заводской номер: 1302337
 Тип системы: А32-00 Система: 1

ТВ1

Дата	T1, (°C)	T2, (°C)	ΔT, (°C)	M1, (т)	M2, (т)	ΔM, (т)	P1, (МПа)	P2, (МПа)	V1, (м³)	V2, (м³)	ΔV, (м³)	Q, (Гкал)	Время работы, (ч)
21.03.26	51.80	46.12	5.68	377.72	377.72	0.00	0.5	0.4	382.06	382.06	0.00	2.143	24.00
22.03.26	51.72	46.05	5.67	377.86	377.86	0.00	0.4	0.4	382.19	382.19	0.00	2.139	24.00
23.03.26	51.00	45.51	5.49	372.60	372.60	0	0.4	0.4	376.76	376.76	0.00	2.046	24.00
24.03.26	50.58	45.17	5.41	369.98	369.98	0	0.4	0.4	374.05	374.05	0.00	2.003	24.00
25.03.26	46.73	42.08	4.65	352.80	352.80	0	0.3	0.4	356.19	356.19	0.00	1.637	24.00
26.03.26	45.77	41.18	4.59	350.34	350.34	0	0.5	0.4	353.54	353.54	0.00	1.617	24.00
27.03.26	44.58	40.34	4.24	342.20	342.20	0	0.4	0.3	345.19	345.19	0.00	1.454	24.00
28.03.26	42.10	38.36	3.74	334.80	334.80	0	0.3	0.3	337.42	337.42	0.00	1.249	24.00
29.03.26	41.60	37.98	3.62	319.94	319.94	0.00	0.3	0.3	322.37	322.39	-0.02	1.157	23.00
30.03.26	41.87	38.19	3.68	335.50	335.50	0	0.4	0.3	338.09	338.09	0.00	1.235	24.00
31.03.26	41.43	37.83	3.60	332.90	332.90	0.00	0.3	0.3	335.42	335.42	0.00	1.196	24.00
01.04.26	42.54	38.74	3.80	336.24	336.24	0.00	0.5	0.3	338.91	338.91	0.00	1.285	24.00
02.04.26	43.59	39.73	3.86	338.27	338.27	0.00	0.4	0.3	341.10	341.10	0.00	1.307	24.00
03.04.26	42.71	38.99	3.72	335.16	334.93	0.24	0.3	0.3	337.87	337.63	0.24	1.235	24.00
04.04.26	41.82	38.22	3.60	332.78	332.78	0	0.3	0.3	335.35	335.35	0.00	1.194	24.00
05.04.26	41.48	37.84	3.64	332.20	332.20	0	0.3	0.3	334.73	334.73	0.00	1.205	24.00
06.04.26	41.08	37.53	3.55	331.81	331.81	0	0.3	0.3	334.28	334.28	0.00	1.174	24.00
07.04.26	41.08	37.42	3.66	332.32	332.32	0.00	0.4	0.3	334.79	334.79	0.00	1.220	24.00
08.04.26	42.79	38.36	4.43	317.39	317.39	0.00	0.3	0.3	319.90	319.90	0.00	1.270	24.00
09.04.26	39.27	35.87	3.40	319.30	319.30	0.00	0.1	0.3	321.48	321.48	0.00	1.021	24.00
10.04.26	38.10	34.76	3.34	318.24	318.24	0.00	0.2	0.3	320.28	320.28	0.00	1.044	24.00
11.04.26	51.36	44.23	7.13	286.61	286.61	0	1.0	0.3	289.72	289.72	0.00	2.075	24.00
12.04.26	50.94	44.06	6.88	281.10	281.10	0.00	0.4	0.3	284.16	284.16	0.00	1.941	24.00
13.04.26	46.19	40.56	5.63	275.58	275.58	0.00	0.3	0.3	278.10	278.10	0.00	1.542	24.00
14.04.26	43.33	39.13	4.20	305.57	305.57	0.00	0.3	0.4	308.09	308.09	0.00	1.271	24.00
15.04.26	42.03	38.00	4.03	311.12	311.12	0	0.4	0.4	313.52	313.52	0.00	1.252	24.00
16.04.26	44.20	39.75	4.45	312.83	312.83	0.00	0.5	0.4	315.48	315.48	0.00	1.394	24.00
17.04.26	42.40	38.33	4.07	315.39	315.39	0	0.3	0.4	317.87	317.87	0.00	1.276	24.00
18.04.26	42.43	38.38	4.05	315.00	315.00	0	0.4	0.4	317.47	317.47	0.00	1.277	24.00
19.04.26	42.35	38.36	3.99	314.67	314.67	0.00	0.3	0.3	317.15	317.15	0.00	1.250	24.00
20.04.26	42.34	38.36	3.98	314.83	314.83	0.00	0.4	0.3	317.30	317.30	0.00	1.254	24.00
Итого	---	---	---	10193.06	10192.83	0.24	---	---	10280.82	10280.60	0.22	44.362	743.00
Среднее	44.23	39.85	4.38	---	---	---	0.4	0.3	---	---	---	---	---

Показания интеграторов

Дата	Мгс	Q, (Гкал)
20.03.26 24:00	99.18	7390.451
20.04.26 24:00	99.18	7434.813
Итого за период	---	44.362

Представитель абонента _____ / _____ Представитель поставщика _____ / _____