

**ТС1 Пульсар ДУ-40, Суточный
с 20.01.26 по 18.02.26**

Объект: г. Октябрьский, Горького, 32
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 05578927
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.01.26	68.1	55.2	86.906	1.097	24.00
21.01.26	68.4	55.5	86.945	1.098	24.00
22.01.26	70.3	56.6	87.391	1.173	24.00
23.01.26	75.0	59.4	87.289	1.330	24.00
24.01.26	77.2	60.7	87.289	1.408	24.00
25.01.26	77.8	61.0	87.211	1.432	24.00
26.01.26	77.9	60.9	87.273	1.450	24.00
27.01.26	77.0	60.4	87.477	1.419	24.00
28.01.26	73.0	57.9	87.742	1.294	24.00
29.01.26	72.2	57.6	87.844	1.254	24.00
30.01.26	72.3	57.9	87.844	1.238	24.00
31.01.26	70.1	56.7	87.750	1.153	24.00
01.02.26	68.2	55.4	87.781	1.101	24.00
02.02.26	68.4	55.7	87.969	1.098	24.00
03.02.26	68.5	55.8	88.070	1.091	24.00
04.02.26	69.3	56.3	87.883	1.125	24.00
05.02.26	70.1	56.4	87.695	1.171	24.00
06.02.26	68.8	55.5	87.641	1.143	24.00
07.02.26	66.0	53.4	87.727	1.083	24.00
08.02.26	65.0	52.9	87.812	1.043	24.00
09.02.26	65.1	53.1	87.891	1.035	24.00
10.02.26	67.1	54.3	87.781	1.100	24.00
11.02.26	68.2	55.1	87.789	1.129	24.00
12.02.26	68.0	54.9	87.805	1.131	24.00
13.02.26	65.3	53.1	87.836	1.053	24.00
14.02.26	63.0	51.5	87.844	0.992	24.00
15.02.26	63.3	51.9	87.875	0.987	24.00
16.02.26	60.8	50.4	87.891	0.901	24.00
17.02.26	58.8	48.9	88.141	0.856	24.00
18.02.26	64.3	52.6	88.258	1.016	24.00
Итого	---	---	2630.648	34.399	720.00
Среднее	68.9	55.6	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.01.26 24:00	72139.227	639.736	19505.000
18.02.26 24:00	74769.875	674.136	20225.000
Итого за период	2630.648	34.400	720.000

Представитель абонента _____/_____

Представитель поставщика _____/_____