

**ТС1 Пульсар ДУ-40, Суточный
с 20.01.26 по 18.02.26**

Объект: г. Октябрьский, Комсомольская, 6
 Потребитель: АО "Жилуправление"
 Прибор: 378 Заводской номер: 02816814
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.01.26	67.0	51.5	72.539	1.103	24.00
21.01.26	67.3	51.8	72.594	1.107	24.00
22.01.26	69.2	52.7	72.859	1.178	24.00
23.01.26	73.8	55.1	72.883	1.336	24.00
24.01.26	76.0	56.0	72.797	1.417	24.00
25.01.26	76.5	56.2	72.812	1.442	24.00
26.01.26	76.6	56.1	72.812	1.455	24.00
27.01.26	75.7	55.7	72.938	1.419	24.00
28.01.26	71.7	53.7	73.117	1.289	24.00
29.01.26	71.0	53.4	72.953	1.257	24.00
30.01.26	71.1	53.7	72.797	1.242	24.00
31.01.26	68.9	52.8	72.766	1.147	24.00
01.02.26	67.1	51.8	72.703	1.092	24.00
02.02.26	67.3	52.1	72.797	1.088	24.00
03.02.26	67.4	52.3	72.875	1.082	24.00
04.02.26	68.3	52.5	72.695	1.120	24.00
05.02.26	68.9	52.5	72.562	1.168	24.00
06.02.26	67.7	51.6	72.602	1.139	24.00
07.02.26	64.9	50.0	72.773	1.065	24.00
08.02.26	63.9	49.6	72.844	1.026	24.00
09.02.26	64.1	49.8	72.859	1.023	24.00
10.02.26	66.1	50.8	72.703	1.091	24.00
11.02.26	67.1	51.5	72.742	1.115	24.00
12.02.26	66.9	51.2	72.820	1.122	24.00
13.02.26	64.2	49.6	72.977	1.043	24.00
14.02.26	62.0	48.3	73.016	0.980	24.00
15.02.26	62.3	48.7	72.992	0.977	24.00
16.02.26	59.7	47.4	73.141	0.889	24.00
17.02.26	57.9	46.1	73.398	0.848	24.00
18.02.26	63.4	49.3	73.297	1.019	24.00
Итого	---	---	2185.664	34.279	720.00
Среднее	67.8	51.8	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.01.26 24:00	73044.617	786.233	24599.000
18.02.26 24:00	75230.281	820.512	25319.000
Итого за период	2185.664	34.279	720.000

Представитель абонента _____ / _____

Представитель поставщика _____ / _____