

**ТС1 Пульсар ДУ-40, Суточный
с 20.01.26 по 18.02.26**

Объект: г. Октябрьский, Чапаева, 7
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 5578692
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
20.01.26	67.3	50.0	39.035	0.662	24.00
21.01.26	67.6	50.3	39.090	0.662	24.00
22.01.26	69.4	51.1	39.234	0.703	24.00
23.01.26	74.1	53.3	39.168	0.792	24.00
24.01.26	76.3	54.3	39.152	0.840	24.00
25.01.26	76.9	54.4	39.141	0.857	24.00
26.01.26	77.0	54.3	39.176	0.865	24.00
27.01.26	76.1	53.9	39.270	0.851	24.00
28.01.26	72.2	51.8	39.402	0.784	24.00
29.01.26	71.4	51.5	39.359	0.765	24.00
30.01.26	71.4	51.7	39.293	0.756	24.00
31.01.26	69.4	51.1	39.250	0.701	24.00
01.02.26	67.4	50.1	39.266	0.667	24.00
02.02.26	67.6	50.3	39.348	0.668	24.00
03.02.26	67.7	50.5	39.395	0.663	24.00
04.02.26	68.5	50.7	39.297	0.684	24.00
05.02.26	69.2	50.8	39.219	0.706	24.00
06.02.26	68.1	50.1	39.211	0.690	24.00
07.02.26	65.3	48.5	39.273	0.647	24.00
08.02.26	64.2	48.0	39.328	0.627	24.00
09.02.26	64.4	48.2	39.348	0.625	24.00
10.02.26	66.3	49.0	39.250	0.666	24.00
11.02.26	67.4	49.7	39.270	0.682	24.00
12.02.26	67.2	49.4	39.250	0.686	24.00
13.02.26	64.6	48.0	39.309	0.642	24.00
14.02.26	62.3	46.6	39.332	0.603	24.00
15.02.26	62.6	47.1	39.324	0.599	24.00
16.02.26	60.1	45.9	39.371	0.550	24.00
17.02.26	58.1	44.7	39.480	0.522	24.00
18.02.26	63.4	47.5	39.473	0.616	24.00
Итого	---	---	1178.312	20.782	720.00
Среднее	68.1	50.1	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
19.01.26 24:00	33006.973	398.699	20216.000
18.02.26 24:00	34185.285	419.481	20936.000
Итого за период	1178.312	20.782	720.000

Представитель абонента _____ / _____

Представитель поставщика _____ / _____