

ТС1, Суточный
с 19.09.25 по 20.10.25

Объект: г. Октябрьский, 34 микрорайон, 4а
Потребитель: АО "Жилуправление"
Прибор: ТЭМ-106 Заводской номер: 3060278
Формула: $Q = M1(h1 - h2)$
Тип системы: Подача + расходомер

Система: 1
ТВ1

	ДУ, мм	Gmin, м3/ч	Gmax, м3/ч	Kv, л/имп	Fmax, КГц
1	50	0	66	0	---
2	50	0	67.10000000 000001	0	---

Дата	Q, (Гкал)	M1, (т)	M2, (т)	dM, (т)	T1, (°C)	T2, (°C)	P1, (МПа)	P2, (МПа)	Время наработки, (ч)
19.09.25	-	-	-	-	-	-	-	-	-
20.09.25	-	-	-	-	-	-	-	-	-
21.09.25	-	-	-	-	-	-	-	-	-
22.09.25	-	-	-	-	-	-	-	-	-
23.09.25	-	-	-	-	-	-	-	-	-
24.09.25	-	-	-	-	-	-	-	-	-
25.09.25	-	-	-	-	-	-	-	-	-
26.09.25	-	-	-	-	-	-	-	-	-
27.09.25	-	-	-	-	-	-	-	-	-
28.09.25	-	-	-	-	-	-	-	-	-
29.09.25	-	-	-	-	-	-	-	-	-
30.09.25	н/д	н/д	н/д	н/д	23.095	22.072	0.2	0.1	н/д
01.10.25	0.571	113.41	110.88	2.5	46.508	41.473	0.6	0.4	24.00
02.10.25	1.034	206.23	205.15	1.1	47.305	42.293	0.6	0.6	24.00
03.10.25	1.095	209.25	208.38	0.9	48.709	43.478	0.7	0.6	24.00
04.10.25	1.173	210.49	209.63	0.9	50.810	45.239	0.7	0.6	24.00
05.10.25	1.168	211.79	211.02	0.8	51.348	45.832	0.7	0.6	24.00
06.10.25	0.939	197.73	197.02	0.7	47.673	42.923	0.6	0.6	24.00
07.10.25	0.760	187.21	186.62	0.6	43.294	39.232	0.6	0.6	24.00
08.10.25	0.757	186.61	186.11	0.5	43.597	39.537	0.6	0.6	24.00
09.10.25	0.741	186.44	186.02	0.4	43.176	39.200	0.6	0.6	24.00
10.10.25	0.736	186.57	186.19	0.4	43.308	39.362	0.6	0.6	24.00
11.10.25	0.738	186.45	186.12	0.3	43.294	39.332	0.6	0.6	24.00
12.10.25	0.731	186.12	185.82	0.3	42.889	38.963	0.6	0.6	24.00
13.10.25	0.719	185.56	185.28	0.3	42.529	38.655	0.6	0.6	24.00
14.10.25	0.828	191.54	191.27	0.3	44.618	40.298	0.6	0.6	24.00
15.10.25	0.951	198.26	197.99	0.3	47.494	42.696	0.7	0.6	24.00
16.10.25	0.932	196.43	196.17	0.3	46.652	41.909	0.7	0.6	24.00
17.10.25	0.953	197.01	196.76	0.3	46.986	42.149	0.7	0.6	24.00
18.10.25	0.915	194.36	194.11	0.3	46.083	41.377	0.6	0.6	24.00
19.10.25	0.870	193.05	192.79	0.3	45.327	40.821	0.6	0.6	24.00
20.10.25	0.907	194.66	194.40	0.3	45.947	41.289	0.6	0.6	24.00
Итого	17.52	3819.2	3807.7	11.8	---	---	---	---	480.00
Среднее	---	---	---	---	44.79	40.39	0.6	0.6	---

Показания интеграторов

Дата	Q, (Гкал)	M1, (т)	M2, (т)	Время наработки, (ч)
18.09.25 24:00	н/д	н/д	н/д	н/д
20.10.25 24:00	5277.3	595850.5	592924.1	98182.7
Итого за период	н/д	н/д	н/д	н/д

Представитель абонента _____/_____

Представитель поставщика _____/_____