

ТВ-7 ТС1, Суточный
с 20.11.25 по 19.12.25

Объект: г. Октябрьский, Матросова, 123
Потребитель: АО "Жилуправление"
Прибор: ТВ7-04.1 Заводской номер: 20140326

БД=1, ТВ1, СИ=6, КТ3=0, ФРТ=0, КСН=0х5А21

Дата	t1, (°C)	t2, (°C)	t3, (°C)	dt, (°C)	P1, (кгс/см2)	P2, (кгс/см2)	P3, (кгс/см2)	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
20.11.25	50.31	42.60	н/д	7.71	2.40	2.42	н/д	74.048	73.473	н/д	73.174	72.858	н/д	0.316	0.564	н/д	24	0
21.11.25	54.17	45.54	н/д	8.63	2.63	2.64	н/д	75.513	74.891	н/д	74.473	74.170	н/д	0.304	0.642	н/д	24	0
22.11.25	46.31	39.92	н/д	6.39	2.04	2.06	н/д	75.381	74.852	н/д	74.626	74.306	н/д	0.320	0.476	н/д	24	0
23.11.25	44.03	38.11	н/д	5.92	1.95	1.97	н/д	75.308	74.802	н/д	74.628	74.307	н/д	0.321	0.441	н/д	24	0
24.11.25	48.23	41.32	н/д	6.91	2.28	2.29	н/д	75.507	74.954	н/д	74.684	74.367	н/д	0.317	0.516	н/д	24	0
25.11.25	44.88	38.84	н/д	6.04	2.30	2.32	н/д	75.522	75.007	н/д	74.813	74.489	н/д	0.324	0.451	н/д	24	0
26.11.25	49.00	41.84	н/д	7.16	2.73	2.75	н/д	75.570	75.016	н/д	74.725	74.412	н/д	0.313	0.535	н/д	24	0
27.11.25	48.08	41.23	н/д	6.85	2.47	2.49	н/д	75.605	75.061	н/д	74.790	74.478	н/д	0.312	0.512	н/д	24	0
28.11.25	49.46	42.09	н/д	7.36	2.35	2.37	н/д	75.458	74.895	н/д	74.594	74.285	н/д	0.309	0.549	н/д	24	0
29.11.25	48.94	41.79	н/д	7.15	2.22	2.23	н/д	75.507	74.954	н/д	74.660	74.351	н/д	0.310	0.533	н/д	24	0
30.11.25	47.63	40.88	н/д	6.76	2.13	2.14	н/д	75.448	74.908	н/д	74.645	74.332	н/д	0.312	0.504	н/д	24	0
01.12.25	48.53	41.38	н/д	7.15	2.10	2.11	н/д	75.400	74.848	н/д	74.567	74.257	н/д	0.310	0.533	н/д	24	0
02.12.25	49.16	41.83	н/д	7.33	2.07	2.09	н/д	75.423	74.863	н/д	74.571	74.260	н/д	0.311	0.546	н/д	24	0
03.12.25	50.90	43.09	н/д	7.81	2.19	2.21	н/д	75.493	74.909	н/д	74.576	74.269	н/д	0.308	0.582	н/д	24	0
04.12.25	51.81	43.80	н/д	8.01	2.22	2.24	н/д	75.531	74.938	н/д	74.585	74.271	н/д	0.314	0.597	н/д	24	0
05.12.25	52.04	43.92	н/д	8.11	2.15	2.17	н/д	75.507	74.913	н/д	74.551	74.241	н/д	0.310	0.605	н/д	24	0
06.12.25	51.88	43.80	н/д	8.08	2.09	2.10	н/д	75.447	74.855	н/д	74.496	74.189	н/д	0.307	0.602	н/д	24	0
07.12.25	52.01	43.94	н/д	8.08	2.05	2.06	н/д	75.408	74.817	н/д	74.454	74.147	н/д	0.306	0.601	н/д	24	0
08.12.25	57.59	47.67	н/д	9.92	2.68	2.69	н/д	75.206	74.538	н/д	74.046	73.749	н/д	0.297	0.734	н/д	24	0
09.12.25	60.69	50.05	н/д	10.64	2.80	2.81	н/д	75.240	74.528	н/д	73.958	73.659	н/д	0.299	0.787	н/д	24	0
10.12.25	59.86	49.38	н/д	10.48	2.50	2.51	н/д	75.642	74.900	н/д	74.385	74.045	н/д	0.341	0.780	н/д	24	0
11.12.25	58.21	48.20	н/д	10.01	2.12	2.13	н/д	75.648	74.904	н/д	74.459	74.089	н/д	0.370	0.745	н/д	24	0
12.12.25	55.09	45.95	н/д	9.14	1.91	1.92	н/д	75.561	74.782	н/д	74.488	74.044	н/д	0.444	0.681	н/д	24	0
13.12.25	52.68	44.22	н/д	8.46	2.07	2.08	н/д	75.617	74.927	н/д	74.637	74.247	н/д	0.389	0.631	н/д	24	0
14.12.25	58.77	48.40	н/д	10.37	3.00	3.01	н/д	75.442	74.667	н/д	74.236	73.851	н/д	0.385	0.769	н/д	24	0
15.12.25	61.30	50.18	н/д	11.12	2.86	2.87	н/д	75.135	73.753	н/д	73.834	72.889	н/д	0.945	0.821	н/д	24	0
16.12.25	61.50	50.25	н/д	11.25	2.29	2.31	н/д	75.248	74.165	н/д	73.934	73.288	н/д	0.646	0.832	н/д	24	0
17.12.25	59.37	48.80	н/д	10.57	2.11	2.13	н/д	75.696	74.809	н/д	74.458	73.976	н/д	0.482	0.787	н/д	24	0
18.12.25	55.41	45.93	н/д	9.48	2.15	2.17	н/д	75.957	75.043	н/д	74.868	74.305	н/д	0.563	0.710	н/д	24	0
19.12.25	52.39	43.67	н/д	8.72	2.00	2.02	н/д	75.874	75.125	н/д	74.896	74.459	н/д	0.436	0.653	н/д	24	0
Итого	---	---	---	---	---	---	---	2263.342	2243.097	---	2233.811	2222.590	---	11.221	18.719	---	720	0
Среднее	52.66	44.28	---	8.38	2.30	2.31	---	---	---	---	---	---	---	---	---	---	---	---

Показания интеграторов

Дата	V1, (м3)	V2, (м3)	V3, (м3)	M1, (т)	M2, (т)	M3, (т)	dM (т)	Qтв, (Гкал)	Qг, (Гкал)	ВНР, (ч)	ВОС, (ч)
19.11.25 24:00	5730.025	5695.624	0.000	5674.290	5651.000	0.000	23.291	24.718	0.000	2487	0
19.12.25 24:00	7993.367	7938.721	0.000	7908.101	7873.589	0.000	34.512	43.436	0.000	3207	0
Итого за период	2263.342	2243.097	0.000	2233.811	2222.589	0.000	---	18.718	0.000	720	0

Представитель абонента _____/_____ Представитель поставщика _____/_____