

**ТС1 Пульсар ДУ-40, Суточный
с 19.02.26 по 20.03.26**

Объект: г. Октябрьский, Горького, 32
 Потребитель: АО "Жилуправление"
 Прибор: 405 Заводской номер: 05578927
 ТВ1

Дата	T1	T2	V1	Q	Время раб. (ч)
19.02.26	66.1	53.7	88.117	1.070	24.00
20.02.26	64.7	52.8	87.891	1.025	24.00
21.02.26	63.6	52.2	89.195	1.005	24.00
22.02.26	63.8	52.2	89.117	1.016	24.00
23.02.26	63.9	52.1	88.953	1.033	24.00
24.02.26	64.5	52.5	88.953	1.047	24.00
25.02.26	63.7	52.1	88.945	1.017	24.00
26.02.26	63.3	51.8	89.031	1.009	24.00
27.02.26	60.0	49.6	88.859	0.907	24.00
28.02.26	58.2	48.4	88.875	0.864	24.00
01.03.26	58.0	48.3	88.891	0.852	24.00
02.03.26	55.4	46.6	88.969	0.772	24.00
03.03.26	55.4	46.6	89.234	0.775	24.00
04.03.26	57.7	48.2	89.062	0.830	24.00
05.03.26	61.2	50.7	89.008	0.923	24.00
06.03.26	62.1	51.4	88.984	0.930	24.00
07.03.26	58.5	48.4	85.062	0.847	23.00
08.03.26	71.3	57.4	86.203	1.175	24.00
09.03.26	74.3	59.4	86.719	1.258	24.00
10.03.26	73.9	58.9	86.695	1.266	24.00
11.03.26	69.1	56.0	87.656	1.119	24.00
12.03.26	62.0	51.2	87.383	0.925	24.00
13.03.26	57.1	47.8	87.977	0.801	24.00
14.03.26	55.4	46.6	88.375	0.765	24.00
15.03.26	55.5	46.7	88.383	0.762	24.00
16.03.26	55.2	46.6	88.531	0.752	24.00
17.03.26	55.5	47.0	89.000	0.752	24.00
18.03.26	53.4	45.5	89.172	0.693	24.00
19.03.26	52.2	44.6	89.164	0.668	24.00
20.03.26	52.5	44.8	89.031	0.671	24.00
Итого	---	---	2651.438	27.526	719.00
Среднее	60.9	50.3	---	---	---

Показания интеграторов

Дата	V1, м. куб	Q, Гкал	Время раб., ч
18.02.26 24:00	74769.875	674.136	20225.000
20.03.26 24:00	77421.312	701.661	20944.000
Итого за период	2651.437	27.525	719.000

Представитель абонента _____ / _____

Представитель поставщика _____ / _____